FI Installation Certificate

FI-2

Site Address	Date Installed
Installing Subcontractor/General Contractor/Owner Signature	

I, the above-signed, verify that the equipment listed on this form is: 1) The actual equipment installed; 2) that specified on the Certificate of Compliance (Form FI-1) which was submitted for incentive eligibility under NSHP; 3) that the shading criteria are as specified in the FI-1

Climate Zone: **3**

Array 1 Azimuth (degrees from North): **90**

Array 2 Azimuth (degrees from North): **180**

Array 3 Azimuth (degrees from North): **270**

Equipment Specifications

Equipment Type	*CEC Certified Manufacturer Name and Model Number*	*Pass/Fail*
Meter Must be built into inverter or on Eligible Equipment List		☐ Pass ☐
Inverter Must be the same as listed on the FI-1		☐ ☐
PV Modules Must be the same as listed on the FI-1		☐ Pass ☐ Fail

PV Modules

Shading

Array	*Quantity*	*Minimally Shaded*[1]	*Annual Solar Access*[2]
#1			
#2			
#3			
Total			

Field Measurements for Performance Verifica

Measurement	*...sed*	*Value Measured*	*Pass/Fail*
Ambient Temperature (°F)			☐ Pass ☐ Fail
Solar Irradiance, Array #1 (W/m			☐ Pass ☐ Fail
Solar Irradiance, Array #			☐ Pass ☐ Fail
Solar Irradi... Array #3 (W/			☐ Pass ☐ Fail

Performance Verifica...

Line	...easurement	*Method Used*	*Value*	*Pass/Fail*
#1	Array #1 Expected Output from Field Verification Table (FVT) #1 (*W*)[3]			
#2	Array #2 Expected Output from Field Verification Table (FVT) #2 (*W*)[4]			
#3	Array #3 Expected Output from Field Verification Table (FVT) #3 (*W*)[5]			
#4	Total Expected Output (*W*)	Sum of Lines #1, #2, #3		
#5	Electric production (*W*) as shown on the inverter or performance meter display			Line #5 ≥ Line #4 ☐ Pass ☐ Fail

1 An array is minimally shaded if each obstruction is at least twice as far from the array as the height it extends above the array

2 The annual solar access is calculated through the use of a solar assessment tool. If minimally shaded, enter 100%

3,4,5 Use the applicable irradiance from the field measurements table along with the ambient temperature. Use the FVTs from the applicable FI-1